

Compliance Statement

No. 2021-227

Data communication cords, Category 6A

Company

Excel
Excel House
Junction Six Industrial Park
Electric Avenue
Birmingham, B6 7JJ
United Kingdom

Product description

Screened Category 6A RJ45 cords LSZH (equipment, patch, and work area) characterised up to 500 MHz

Product identification

Excel Category 6A Screened (F/FTP) Patch Lead

Generic cabling and cabling components standard - Category 6A balanced cord requirements

- ISO/IEC 11801-1:2017 (Ed. 1.0) / ISO/IEC 11801-2:2017 (Ed. 1.0)
- EN 50173-1:2018 / EN 50173-2:2018
- TIA-568.2-D:2018
- IEC 61935-2:2010 (Ed. 3.0) (transmission requirements)

Technical report

12122139-01, DANAK-19/21819

EC Cabling product ID


5524

CS valid until

1 May 2022

This product has been tested by FORCE Technology and complies with the electrical requirements of the above specified standards and "Terms and conditions for the EC VERIFIED programme for Generic and Coaxial Cabling", DQP231006. The product takes part in a maintenance of certification schedule, which implies that FORCE Technology performs a sample test of the product once a year.

Hørsholm, 4 March 2021



Lars Lindskov Pedersen
Test Manager



Dennis Andersen
Head of Department

